

DOC11R

**Case Management System - KY Public Service Commission**

*Regular Cases Before the Commission as of April 06, 2025*

**2017-00307**

RECEIVED: 08/18/17

FILED: 08/18/17

FINAL: 01/31/18

REOPENED:

SUSPENSION DATE:

**CASE CODE**

Deviation

**UTILITIES:**

Wood Creek Water District

**INDEX OF EVENTS:**

- 01/31/18 Final Order Entered: 1. WCWD's Application proposing an alternative inspection schedule for its grinder/pump stations pursuant to 807 KAR 5:071, Section 7(4), is approved. 2. Simplex grinder/pump stations shall be inspected annually.
- 10/23/17 Wood Creek Water District Response to Request for Information
- 10/19/17 Larry G. Bryson Wood Creek Water District Response to Commission Staffs First Request for Informatoin
- 10/10/17 Commission Staff's First Request for Information to Wood Creek Water District
- 08/15/17 Larry G. Bryson Wood Creek Water District Application for Wood Creek Water District Pursuant to 807 KAR 5:071, Section 7(4) for Approval of Proposed Inspection Procedures
- 07/24/17 Letter Updating Proposed File Date
- 07/21/17 Acknowledge Receipt of Filing
- 07/21/17 Wood Creek Water District Notice of Intent to File Application Pursuant to 807 KAR 5:071, Section 7(4) for Approval of Proposed Inspection Procedures Using Electronic Filing Procedures

Total Number of Cases: 1