

DOC11R

Case Management System - KY Public Service Commission*Regular Cases Before the Commission as of April 18, 2025***2024-00380**

RECEIVED: 11/27/24

FILED: 11/27/24

FINAL: 01/30/25

REOPENED:

SUSPENSION DATE:

CASE CODE

Deviation

UTILITIES:

Dexter-Almo Heights Water District

INDEX OF EVENTS:

01/30/25	Final Order Entered: 1. Dexter-Almo Heights District's request to deviate from the water storage requirements of 807 KAR 5:066, Section 4(4), is approved through December 31, 2026. 2. Dexter-Almo Heights District shall inform the Commission if changes occur in either system that would cause Murray to have insufficient storage for Dexter-Almo Heights District. 3. Any documents filed in the future pursuant to ordering paragraph 2 of this Order shall reference this case number and shall be retained in the post-case correspondence file. 4. This case is closed and removed from the Commission's docket.
11/27/24	Jasper Wyatt Dexter Almo Heights Water District Application for Deviation from 807 KAR 5:066, Section 4(4)
11/25/24	Acknowledge Receipt of Filing
11/22/24	Dexter-Almo Heights Water District Notice of Intent to File an Application for a Deviation from 807 KAR 5:066, Section 4(4) Using Electronic Filing Procedures

Total Number of Cases: 1