

For: \_\_\_\_\_

PSC KY Number: \_\_\_\_\_

\_\_\_\_\_ Sheet No. \_\_\_\_\_

Cancelling PSC KY Number: \_\_\_\_\_

\_\_\_\_\_ Sheet No. \_\_\_\_\_

\_\_\_\_\_  
*(Name of Utility)*

Service Lines.

1. The service line is the pipe from the outlet side of the water meter to the point of usage. The applicant/customer owns and is responsible for the service line from the outlet side of the water meter (or point of service) to the point of usage, must furnish and lay the necessary pipe of the service line, and is financially responsible for all costs associated with the installation and maintenance of the service line plumbing.
2. The service line shall be laid at least thirty (30) inches in depth, shall not be less than three-fourths (3/4) inch in size, and shall be installed, maintained, and repaired in accordance with all applicable statutes, regulations, and codes.
3. The service line trench shall be left open and the pipe uncovered to allow the utility to visually inspect the connecting line. The utility may substitute for its inspection an inspection by the appropriate state or local plumbing inspector, if proof of that inspection is presented to the utility by the applicant/customer.
4. If the applicant/customer has a point of usage at a higher elevation than the meter, he/she shall consult with an engineering firm to properly size the service line from the meter to the point of usage.
5. If the applicant/customer desires a higher than normal pressure, he/she shall make provisions for an individual pressure booster system for the service line, subject to approval by the utility. The utility reserves the right to require discontinuance and disconnection should the private booster system have a detrimental effect on the utility's system.
6. If the applicant/customer has boilers and/or pressure vessels that receive water from the utility, he/she shall provide a check valve on the water supply line and a vacuum valve on the steam line in order to prevent a collapse were the water supply from the utility be interrupted or discontinued.
7. If the applicant/customer has used or is using a well, he/she shall provide the utility access to perform an inspection to verify the well is properly separated from the system.

DATE OF ISSUE \_\_\_\_\_  
*Month / Day / Year*

DATE EFFECTIVE \_\_\_\_\_  
*Month / Day / Year*

ISSUED BY \_\_\_\_\_  
*(Signature of Officer)*

TITLE \_\_\_\_\_

BY AUTHORITY OF ORDER OF THE PUBLIC SERVICE COMMISSION  
IN CASE NO. \_\_\_\_\_ DATED \_\_\_\_\_